

**Kirkwood Meadows Public Utility District – Wintergreen Sewer Replacement**

**BID ADDENDUM NO. 1**

Specification No.: \_\_\_\_\_

Date: July 24, 2024

**QUESTIONS:**

1. Please provide the Engineer's Estimate for the Project.

**The Engineer's Estimate is \$105,000.00**

2. Can the trees required to be removed be chipped and spread onsite?

**The Contractor may, at their option, remove trees in the pipeline replacement area as required by the Plans and as required for access to the work, chip all removed wood and spread the wood chippings within the KMPUD easement. No piles of wood chips will be allowed. If any portions of trees removed cannot be chipped, they must be removed and disposed of offsite as indicated in the Plans. The Contractor shall include in their bid removal of all trees 10' either side of the pipe section to be replaced as indicated in the Plans and all trees necessary to be removed to establish access to and for the work through the existing easement. Any trees removed may be cut off within six (6) inches of ground level. Existing stumps and stumps created with tree removal as part of this work do not need to be removed.**

3. Will KMPUD consider replacement of the sewer pipe section via pipe bursting?

**KMPUD requires replacement of the section as indicated and detailed in the Plans.**

**End of Addendum No. 1**