



IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene informacion muy importante sobre su agua potable.
 Por favor hable con alguien que lo pueda traducir.

**Perchlorate Monitoring Requirements
 Not Met for Kirkwood Meadows Public Utility District During the
 Calendar Year of
 2015 and 2016**

District staff failed to monitor for a specific contaminant as required for drinking water standards during the calendar years of 2015 and 2016 and, therefore the District was in violation of the regulations. Although this is not an emergency, as our customers, you have the right to know what happened, what you should do, and what the District did to correct the situation.

What happened?

The District is required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not District drinking water meets health standards. During the calendar years of 2015 and 2016, District staff did not monitor and report a perchlorate sample result from Well 2, Well 4, and Well 5 and therefore, cannot be sure of the quality of our drinking water relative to this one constituent during that time.

What should I do?

- There is nothing you need to do at this time.
- The table below lists the contaminant District staff did not properly test for during the calendar years 2015 and 2016; how many samples we are required to take and how often; how many samples the District took; when samples should have been taken: and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were taken
Perchlorate	Once every Three years	None	Well 02-2016 Well 04-2015 Well 05-2015	Well 02-2017 Well 04-2017 Well 05-2017

- If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

Clerical oversight caused the failure to sample perchlorates at the designated sampling sites within the compliance monitoring period. Samples taken in 2017 from these sites were non-detect for perchlorate as were all samples taken in previous years. The District will comply with all compliance monitoring requirements mandated by the water permit and Title 22 California Code of Regulations immediately.

For more information, please contact Derek Dornbrook at 209-258-4444 or at ddornbrook@kmpud.com.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS:** Must notify tenants (including nursing homes and care facilities.)
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you in compliance with the California Domestic Water Quality and Monitoring Regulations as a means of keeping the public informed.

This notice is being sent to you by Kirkwood Meadows Public Utility District.

State Water System ID: 0210002. Date Distributed: July 12, 2018.